



Howler UK

Howler Battery Operated Site Fire Alarm

Data Sheet

	HM Range	HO Range	SA01
Dimensions	197diam x 105mm deep	200w x 300h x 120d mm	160w x 260h x 75d mm
Volume	98dB at 1000mm	101dB at 1000mm	98dB at 1000mm
Power Source	9V PP9 Battery	9V PP9 Battery	9VPP3 Battery
Casing Material	Aluminium	ABS Plastic	ABS Plastic

Switch Type	Method of operation	IP rated switch?
HO1/HM1/SA01	Push on / Push off	Yes
HO2/HM2	Push on / Twist off	Yes
HO3/HM3	Push on / Key off	Yes
HO4/HM4	Push on / Push off - illuminated	Yes
HOCP/HMCP	Key-resettable call point switch	No

Suffixes	
/ML Eg HO1/ML	Linking method Two core cable – minimum 0.5mm ² core
/XS	Red Strobe Option
/BT	Battery Test Option

EC Certification

Electromagnetic Compatibility Tested

EN 55022: 1998	EN 50130-4: 1995
Emissions	Immunity

Certificate of Testing No: 6169/06

EA Producer Registration Number: WEE/HF0065TW

Country of Origin: Great Britain

E&OE© Howler 04/11

*Specification may be subject to change without prior notice